

Pool Chemistry Requirements

Disinfectant	Swimming Pools	Wading Pools	Spa Pools
Free Chlorine	2.0 - 10.0 ppm	3.0 - 10.0 ppm	3.0 - 10.0 ppm
Combined Chlorine	≤ 0.5 ppm	≤ 0.5 ppm	≤ 0.5 ppm
Bromine	4.0 - 20.0 ppm	6.0 - 20.0 ppm	6.0 - 20.0 ppm

Other Chemical Qualities	Required	Ideal
pH	7.2 - 7.8	7.4 - 7.6
Alkalinity	≥ 50 ppm	80 - 120 ppm
Cyanuric acid	≤ 60 ppm	< 30 ppm
Calcium hardness		200 - 400 ppm
Temperature	≤ 104°F	
Water clarity	Main drain visible	

For reasonable accommodations or alternative formats please contact 311 at 612-673-3000.
 People who are deaf or hard of hearing can use a relay service to call 311 at 612-673-3000.
 TTY users call 612-263-6850. Para asistencia, llame al 612-673-2700 - Rau kev pab 612-673-2800 Hadii aad Caawimaad u baahantahay 612-673-3500.