

# Water Quality Log

Pool Name \_\_\_\_\_

Year \_\_\_\_\_

Type of Pool   Standard   Spa   Wading   Therapy   Other \_\_\_\_\_

Keep log for six years.

Date	Time of Day	Disinfectant		pH	Flow Rate	Temp	Alk	CYA	Filter PSI	Check Drain Covers?	Comments (Chemical Adjustments, Backwash, Injuries, Accidents)	CTO Init.
		Free	Combined									
5/20	10am	4.6	0.2	7.4	200	86	70	40	24	<input checked="" type="checkbox"/>	Backwashed for 10 minutes	EX
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		

<b>Free Chlorine</b> Pool: 2-10 ppm Spa: 3-10 ppm	<b>Combined Chlorine</b> < 0.5 ppm	<b>Bromine</b> Pool: 4-20 ppm Spa: 6-20 ppm	<b>pH</b> 7.2-7.8	<b>Alkalinity (Alk)</b> > 50 ppm	<b>Cyanuric Acid (CYA)</b> < 60 ppm	<b>Turnover Time</b> Pool: < 6 hours    Wading: < 2 hours Spa: < 30 Min.	<b>Temp</b> < 104°
---	---------------------------------------	---	----------------------	-------------------------------------	--	--	-----------------------

For reasonable accommodations or alternative formats please contact the Health Department at 612-673-2301 or by email at [health@minneapolismn.gov](mailto:health@minneapolismn.gov). People who are deaf or hard of hearing can use a relay service to call 311 at 612-673-3000. TTY users can call 612-673-2157 or 612-673-2626. Para asistencia 612-673-2700 • Rau kev pab 612-673-2800 • Hadii aad Caawimaad u baahantahay 612-673-3500.