



NOTES:

1. TWO GROUND RODS (1/2" X 8") ARE REQUIRED ON ALL SERVICE CABINETS.
2. ALL FOUNDATION LOCATIONS SHALL BE DETERMINED IN FIELD BY TRAFFIC DIVISION AT TIME OF CONSTRUCTION.
3. FOUNDATION TOP SHALL BE EDGED, BROOMED AND BE FINISHED ON ALL SIDES.

① KEEP SERVICE FEED TO LEFT OF BARRIER.

② 3" FROM HIGHPOINT OF FINISHED SIDEWALK GRADE, 4" FROM HIGHPOINT OF FINISHED BOULEVARD GRADE.

③ PROVIDE PROTECTIVE BUSHINGS ON ALL CONDUITS, 1" MINIMUM, 2" MAXIMUM ABOVE FOUNDATION TOP.

④ CABINET ANCHORS ARE WEDGE ANCHORS, 4 PER CABINET, 1/2" X 4 1/2" STAINLESS STEEL (#304) FULL THREADED.