



Water quality log

Pool name _____

Year _____

Pool type Standard Spa Wading Therapy Other _____

Keep log for six years.

Date	Time	Disinfectant		pH	Flow rate	Temp	Alk	CYA	Filter PSI	Check drain covers?	Comments (Chemical adjustments, backwash, injuries, accidents)	CTO init.
		Free	Combined									
5/20	10am	4.6	0.2	7.4	200	86	70	40	24	<input checked="" type="checkbox"/>	Backwashed for 10 minutes	EX
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		
										<input type="checkbox"/>		

Free chlorine Pool: 1-10 ppm Spa: 2-10 ppm Wading w/shower: 1-10 ppm Wading w/o shower: 2-10 ppm	Combined chlorine < 0.5 ppm	Bromine Pool: 2-20 ppm Spa: 4-20 ppm Wading w/shower: 2-20 ppm Wading w/o shower: 4-20 ppm	pH 7.2-7.8	Alkalinity (Alk) > 50 ppm	Cyanuric acid (CYA) < 100 ppm	Turnover time Pool: < 6 hours Wading: < 2 hours Spa: < 30 Min.	Temp < 104°
---	---------------------------------------	---	----------------------	-------------------------------------	---	--	-----------------------

minneapolismn.gov/pools

Last updated 10/29/2024

For reasonable accommodations or alternative formats please contact Environmental Health at health@minneapolismn.gov or 612-673-2301. People who are deaf or hard of hearing can use a relay service to call 311 at 612-673-3000. TTY users call 612-263-6850. Para ayuda, llame al 311. Rau kev pab 311. Hadii aad Caawimaad u baahantahay wac 311.