



- NOTES:
- ① EXPANSION MATERIAL REQUIRED (SEE MNDOT SPEC BOOK, 2301.3K JOINT CONSTRUCTION).  
FIRST SECTION NEXT TO COMMERCIAL DRIVEWAY OR ALLEY 6" THICK.  
1/2" THICK EXPANSION JOINTS AT 30' INTERVALS (MAXIMUM).  
EXPANSION TO BE USED WHEN SIDEWALK ABUTS:
    - BUILDING,
    - CURB,
    - OTHER PAVEMENTS INDICATED ON GRAPHIC ABOVE.
  - ② CONTRACTION JOINT TO BE CENTERED ON SIDEWALK WIDER THAN 9'.  
CONTRACTION JOINT TO BE PLACED EVERY 6' OR LESS.
  - ③ DEVELOPMENT PROJECTS SHALL PLACE AND COMPACT 4" OF CLASS 5 AGGREGATE UNDER THE NEW SIDEWALK.
  - ④ SLOPE TOWARD ROADWAY, 3/16" PER FT. TYPICAL, 1/4" PER FT. MAX. AS CONSTRUCTED.
  - ⑤ TREE ROOT ZONE SPACING REQUIREMENTS 2571.X MAY DICTATE GRASS IN LIEU OF CONCRETE.

	DRW: JFC	DATE: 12/27/19	TYPICAL SIDEWALK AND DRIVEWAY CONSTRUCTION	STANDARD PLATE NO. ROAD-2003-R2
	APP: JSH	DATE: 3/25/20		