



RING & COVER FACE SHALL BE FREE OF CONCRETE AFTER FINISHING

RING & COVER PER MPLS. STD. PLATE TRAF-1715

40" SQ. PAD OR MATCH EXISTING SIDEWALK

MATCH EXISTING GRADE

2" PVC TO BASE OF TREE WITH 12/2 W/ GROUND NUCC OR LFNC

FESTOON CIRCUIT #4 COMBO

EXTEND CONDUITS 1" MIN TO 2" MAX INSIDE HAND HOLE

25 1/2" DIA. REF.  
18" DIA. REF.  
1 1/2" REF.

2" PVC TO LOW LEVEL STREET LIGHT FOUNDATION  
2" PVC TO BASE OF TREE WITH 12/2 W/ GROUND NUCC OR LFNC

30"

FESTOON CIRCUIT #4 COMBO

18" I.D. x .449 THK 2'-6" LONG PVC PIPE

DRAIN FIELD IF SPECIFIED  
FILL WITH 1-1/2" MAX. GRAVEL

NOTE:  
LIMIT 5 - 6 CONDUITS PER HAND HOLE

APPROX. 24" DIA

NO SCALE

	DRW: EAV	DATE: 11/1/19	<b>HANDHOLE - FESTOON</b> 18" DIA. X 30" - STEEL INSTALLATION DETAIL REFERENCE PLATE: TRAF-1715	STANDARD PLATE NO. TRAF-3725-R2
	APP: DRP	DATE: 11/1/19		