



Minneapolis Water Works

Monthly Plant Effluent Water Analysis for:

August 2024

Physical and Chemical Water Quality

	<u>Plant Effluent Average Value</u>
Temperature, River Water Average (°C)	25.9
Total Organic Carbon (ppm* as C)	5.01
Total Dissolved Solids (ppm)	149
Turbidity (NTU)	0.05
Alkalinity-Total (ppm as CaCO ₃)	52
Ammonia Nitrogen (ppm as N)	0.95
Total Chloramine Residual (ppm as NH ₂ Cl)	3.9
Fluoride-F (ppm as F)	0.68
pH	9.05
Nitrate - NO ₃ (ppm as N)	0.77
Nitrite - NO ₂ (ppm as N)	<0.015
Phosphate-PO ₄ (ppm as PO ₄)	0.63
Sulfate - SO ₄ (ppm as SO ₄)	27.7
Total Hardness (grains per gallon) EDTA method	4.9
Total Hardness (ppm as CaCO ₃) EDTA method	83

Chemical Water Quality - Inorganic Metals

	<u>Plant Effluent Average Value</u>
<u>Chemical Element</u>	
Aluminum-Al (ppm as Al)	0.04
Arsenic-As (ppm as As)	Not Detected
Cadmium-Cd (ppm as Cd)	Not Detected
Calcium-Ca (ppm as Ca)	28.1
Chloride-Cl (ppm as Cl)	28.2
Chromium (ppm as Cr)	<0.01
Copper-Cu (ppm as Cu)	<0.01
Iron-Fe (ppm as Fe)	Not Detected
Lead-Pb (ppm as Pb)	Not Detected
Magnesium-Mg (ppm as Mg)	1.13
Manganese-Mn (ppm as Mn)	<0.01
Silica-Si (ppm as SiO ₂)	8.6
Sodium-Na (ppm as Na)	13.4
Zinc-Zn (ppm as Zn)	<0.01

*ppm = parts per million