

Minneapolis Water Works

Monthly Plant Effluent Water Analysis for:

February 2025

Physical and Chemical Water Quality

	<u>Plant Effluent Average Value</u>
Temperature, River Water Average (°C)	2.9
Total Organic Carbon (ppm* as C)	3.30
Total Dissolved Solids (ppm)	175
Turbidity (NTU)	0.05
Alkalinity-Total (ppm as CaCO ₃)	53
Ammonia Nitrogen (ppm as N)	0.91
Total Chloramine Residual (ppm as NH ₂ Cl)	4.1
Fluoride-F (ppm as F)	0.71
pH	9.06
Nitrate - NO ₃ (ppm as N)	1.30
Nitrite - NO ₂ (ppm as N)	<0.015
Phosphate-PO ₄ (ppm as PO ₄)	0.74
Sulfate - SO ₄ (ppm as SO ₄)	30.5
Total Hardness (grains per gallon) EDTA method	5.4
Total Hardness (ppm as CaCO ₃) EDTA method	93

Chemical Water Quality - Inorganic Metals

<u>Chemical Element</u>	<u>Plant Effluent Average Value</u>
Aluminum-Al (ppm as Al)	Not Detected
Arsenic-As (ppm as As)	Not Detected
Cadmium-Cd (ppm as Cd)	Not Detected
Calcium-Ca (ppm as Ca)	29.1
Chloride-Cl (ppm as Cl)	37.2
Chromium (ppm as Cr)	<0.01
Copper-Cu (ppm as Cu)	<0.01
Iron-Fe (ppm as Fe)	Not Detected
Lead-Pb (ppm as Pb)	Not Detected
Magnesium-Mg (ppm as Mg)	5.56
Manganese-Mn (ppm as Mn)	<0.01
Silica-Si (ppm as SiO ₂)	9.5
Sodium-Na (ppm as Na)	20.5
Zinc-Zn (ppm as Zn)	<0.01

*ppm = parts per million
Last Updated 1/15/2025