



Minneapolis Water Works

Monthly Plant Effluent Water Analysis for:

May 2023

Physical and Chemical Water Quality

	<u>Plant Effluent Average Value</u>
Temperature, River Water Average (°C)	19.0
Total Organic Carbon (ppm* as C)	4.48
Total Dissolved Solids (ppm)	168
Turbidity (NTU)	0.05
Alkalinity-Total (ppm as CaCO ₃)	69
Ammonia Nitrogen (ppm as N)	0.85
Total Chloramine Residual (ppm as NH ₂ Cl)	3.9
Fluoride-F (ppm as F)	0.77
pH	9.05
Nitrate - NO ₃ (ppm as N)	0.90
Nitrite - NO ₂ (ppm as N)	<0.015
Phosphate-PO ₄ (ppm as PO ₄)	0.86
Sulfate - SO ₄ (ppm as SO ₄)	27.4
Total Hardness (grains per gallon) EDTA method	6.14
Total Hardness (ppm as CaCO ₃) EDTA method	105

Chemical Water Quality - Inorganic Metals

<u>Chemical Element</u>	<u>Plant Effluent Average Value</u>
Aluminum-Al (ppm as Al)	0.13
Arsenic-As (ppm as As)	Not Detected
Cadmium-Cd (ppm as Cd)	Not Detected
Calcium-Ca (ppm as Ca)	39.5
Chloride-Cl (ppm as Cl)	22.4
Chromium (ppm as Cr)	<0.01
Copper-Cu (ppm as Cu)	<0.01
Iron-Fe (ppm as Fe)	Not Detected
Lead-Pb (ppm as Pb)	Not Detected
Magnesium-Mg (ppm as Mg)	0.54
Manganese-Mn (ppm as Mn)	<0.01
Silica-Si (ppm as SiO ₂)	7.7
Sodium-Na (ppm as Na)	14.3
Zinc-Zn (ppm as Zn)	<0.01

*ppm = parts per million